

To

Sir,

Sealed limited tenders are invited in two bid system for the supply, installation and commissioning of **Two numbers of 3TR Floor standing Air Conditioners in the Data Center** server Room of Regional Cancer Centre, Trivandrum. The tender should be submitted in two bid system ie technical bid and financial bid separately. Both envelopes should be properly sealed and should bear the superscription "Limited tender No46/RCC/16:17/P5 and should be addressed to the Director, Regional Cancer Centre, Trivandrum 695011.

The technical bid should contain

- Detailed technical specification of the product quoted
- Brochure or literature
- EMD or EMD exemption certificate
- Details of service facility in Trivandrum
- Delivery and commissioning period
- Payment condition
- Warranty

The financial bid (price bid) should contain

Total Price of the A/C, If VAT is extra, % of VAT should be clearly mentioned.

The tenders duly signed and sealed in each page by the tenderer along with necessary documents shall be submitted to the Director, Regional Cancer Centre, Trivandrum - 695011 on or before **4PM on 27/03/2017(Monday)**. Late tenders will not be accepted. The tenderer should enclose the Earnest Money Deposit (EMD) amount of **Rs.1500/-** by way of Demand draft/Bank Guarantee/Fixed Deposit in favour of Director, RCC, and Trivandrum along with the technical bid which is refundable. EMD is exempted in the following cases. If the tenderer comes in any of the following category, they should submit a self-attested copy of the relevant certificate along with the technical bid for EMD exemption.

Firms who are registered with the Stores Purchase Department or the Directorate General of Supplies and Disposals, New Delhi are exempted from furnishing EMD for tenders in respect of stores by which they have registered as suppliers of stores.

- Micro and small enterprises and Industrial Co-operatives within the Kerala State which are certified as such by the Director of Industries and Commerce or by the General Manager, District Industries Centre are exempted in respect of certified items from furnishing EMD in support of tenders.
- The Khadi and Village Industries Co-operative Societies and the Institutions registered

under the Travancore Cochin Literary, Scientific and Charitable Societies Registration Act, 1955 within Kerala State which are certified as such by the Secretary, Kerala Khadi and Village Industries Board are exempted from furnishing EMD in support of tenders.

- Micro, Small & Medium enterprises registered with the National Small Industries Corporation Limited, New Delhi and in respect of which competency certificates are issued by the Corporation will be exempted from payment of EMD.
- Government Institutions/Kerala State Public Sector Undertakings which manufacture and supply stores are exempted from furnishing EMD.
- Kerala State Small Industries Development Corporation Ltd when it participates in tender on behalf of Small Scale Units will be exempted from furnishing EMD.

The technical bids will be opened at 12 Noon **28/03/2017(Tuesday)** in the presence of such of the tenderers or their authorized representatives who may be present at that time. The financial bids of technically qualified firms will be opened after technical evaluation and the date will be intimated to the technically qualified tenderers.

Name of equipment – Two numbers of 3TR Floor standing Air Conditioners

Specification of the 3TR Floor standing A/C is given below: (Qty : Two)

I. The AC units for DATA centre server room shall be sent to maintain the following inside conditions.

DBT 22 Deg C+2 Deg C

The operation range should be 16 °C- 50 °C approx.

II. The Floor standing air conditioning units should be of the following features.

- Unit should be of auto start facility
- Self-diagnostic and auto protection system
- Auto swing facility
- Timer facility
- Sleep mode facility
- Rust free cabinet with lockable arrangement
- The Panel should be cleanable with a wired controller
- Humidifier should be independent
- The unit should be with indoor and outdoor facility

III. For better performance and efficiency, Inverter air conditioning systems are required.

- The compressor should be of twin rotary inverter compressor
- The compressor warranty should be minimum 3 year
- Warranty for the air conditioner- minimum 12 months .

Other requisite works to be included in the contract

- Copper refrigerant piping complete with insulation between the indoor and remote outdoor units as required.
- Digital Timer Sequencing facility for synchronizing the units and is also have the capability for failover (Digital Control panel)
- PVC drains piping from the indoor units up to the nearest drain point to be done.
- Electrical Power from the Electrical panel and control cables between the indoor unit and outdoor unit and earthing

- GI brackets (powder coated) for outdoor condensing unit and proper earthing if necessary.

Terms and conditions:-

1. The brand new model of 3TR Floor standing A/C shall be quoted and supplied.
2. The make and model of the item should be clearly specified
3. The offer should be valid up to 31st JUNE 2017
4. Director of Regional Cancer Centre, Trivandrum reserves the right to accept or reject all or any tender at his sole discretion without assigning any reasons. For legal purposes, the cause of action will be deemed to have arisen in Trivandrum, Kerala state
5. Any attempt on the part of tenderers or their agents to influence the officers concerned in their favour by personal canvassing will disqualify the firm
6. If the contract is awarded, they have to submit an agreement in Kerala Stamp paper worth Rs.200 and a security deposit of 5% of the total value of the order within 15 days from the date of receipt of supply order. This deposit amount will be refunded after the expiry of contract successfully
7. Installation: Installation should be done by the supplier at free of cost
8. Payment:- Payment will be released within a maximum period of 90 days from the date of successful commissioning & certification by the end user . RCC has an option to make the payment within 30 days from the date of successful commissioning and final acceptance by RCC, provided 3% of the total bill amount will be deducted. If the tenderer wishes to avail this benefit, that should be mentioned in the offer.
9. Penalty: If it is delayed beyond 15 days, RCC will charge a penalty of 0.05% of the total value per day for the first 30 days and thereafter 0.06% per day.
10. Delivery period:- All items as per the supply order shall be supplied, installed and Commissioned in the DATA center server room for new Block OP/IP of RCC to their Satisfaction within 15 days from the date of supply order.

Thiruvananthapuram

14/03/2017

DIRECTOR